

### Stucco/Parging

Trade Contractor \_\_\_\_\_ Job Name, Number \_\_\_\_\_

#### Pass/Fail/NA

- All work complies with locally adopted codes and International Residential Code.
- All work is performed in a safe manner according to OSHA standards.
- The jobsite is left clean including mortar bags and leftover stucco.
- Trash is cleaned up and disposed of.
- Stucco/parging is applied  $\frac{3}{8}$ " thick.
- All doors and windows, freon lines, and hose spigots are set before applying stucco.
- Final grading, concrete porches, and flatwork are complete before applying stucco.
- Soil is removed down 6" all around foundation before applying stucco to ensure adequate coverage. Dirt and hay are replaced when stucco is finished.
- Stucco is neatly applied around the edges of door and window openings, downspouts, and foundation vents, and is not smeared on them.
- All forms are removed and stucco is applied to the edges and sides of all porches and carport slabs where they are exposed.
- Stucco is kept out of patio door tracks and door sills.
- All stucco is wiped off door frames, window frames, light fixtures, receptacles, etc.
- Stucco goes straight up to bottom edge of siding and is not too thick against bottom edge of siding. All siding is left clean.

#### Stucco Mixture

1 Bag of Portland Cement

2 Bags of Masonry Cement

35 Shovels of Sand

The Trade Contractor understands and accepts responsibility for items on this checklist and verifies that these items have been checked and are acceptable. In the event that these items are not completed to our satisfaction, the Trade Contractor agrees, upon notification, to correct the unsatisfactory items promptly, or gives the company the right to correct the item and back charge the Trade Contractor accordingly. I hereby verify that the above items have been checked and are acceptable. I understand that this checklist must be turned in with the invoice in order to receive payment on this job.

Signature \_\_\_\_\_ Date \_\_\_\_\_